

# **Industrial Flow Solutions Operating, LLC**

## **PUMP SPECIFICATION**

### **KZE HEAVY DUTY SLURRY PUMPS**

#### **PUMP REQUIREMENTS**

Supply (qty) \_\_\_\_, 8 inch discharge BJM Pumps electric submersible heavy duty slurry pump(s). The pump shall be driven by a close-coupled \_\_\_\_ HP, submersible electric motor with a nominal rating of \_\_\_\_ Volts, \_\_\_\_ Ph, 60 Hz, 1750 rpm.

The pump shall be capable of delivering \_\_\_\_ US GPM flow at \_\_\_\_ FT TDH. The pump shall also be able to delivering \_\_\_\_ US GPM at \_\_\_\_ FT TDH. The pump shutoff head shall not be less than \_\_\_\_ FT TDH.

#### **DESIGN AND CONSTRUCTION**

The pump shall be designed and constructed to pump liquids containing up to 70% (concentration by weight) abrasive solids without causing excessive wear or early pump failure.

##### **Agitator**

The pump shall be designed and fitted with a replaceable hard metal agitator to lift solids that have settled to the bottom of the pumping area, and to move these solids into suspension with the pumped liquid. The agitator design shall have at least 4 conical vanes to create continuous agitation beneath the pump and keep solids in suspension. The agitator shall be constructed of 25% chrome iron with hardness of at least 653 BHN. The agitator shall be attached directly to the pump shaft at the eye of the pump impeller.

##### **Suction Cover (Wear Plate)**

The pump shall be supplied with a hardened suction cover to prevent erosion; a condition that would reduce the pump's hydraulic performance. The suction shall be replaceable, constructed of 25% chrome iron with a minimum hardness of 653 BHN, and installed in front of the impeller.

##### **Impeller**

The pump shall be supplied with a 25% chrome iron with a minimum hardness of 653 BHN, multi-vane, semi-open type impeller. The impeller shall be dynamically balanced and designed for superior hydraulic efficiency. Each impeller shall be capable of handling 1.3 inch (33 mm) diameter spherical solids without clogging.

##### **Volute**

The volute casing design shall be semi-concentric to reduce radial loads. The volute shall be constructed from 25% chrome iron with a minimum hardness of 653 BHN.

# BJM PUMPS, LLC

## PUMP SPECIFICATION

### KZE HEAVY DUTY SLURRY PUMPS

#### Seals

The pump shall be supplied with four independent seals designed to prevent fluid from entering the motor housing.

The pump seal chamber shall be isolated from the pumped liquid by a lip seal constructed from Buna N Rubber.

A double set of mechanical shaft seals shall be installed in an oil filled seal chamber. The seal chamber shall be designed to permit inspection & drainage, and to prevent over-filling, without disassembly of the pump stand, agitator and impeller.

Both mechanical seals shall be hydro dynamically lubricated by an ISO 32 NSF mineral oil.

The seal faces in the mechanical seal shall be constructed of Silicon Carbide. The rotating and stationary seal faces in the two seals shall be held in contact by a common 304SS spring.

The power cable entry shall be sealed by a compression fitting utilizing an NBR grommet in close tolerance with the power cable, attached to the motor cover. The power cable wire leads shall be independently connected to the motor wire leads using uninsulated butt connectors in an epoxy potting. The potting shall be done in a manner to establish an anti-wicking block. Each wire lead shall have its insulation stripped, exposing the copper conductor. Leads shall be connected using an uninsulated butt connector, and then completely covered with epoxy potting material to form a solid barrier.

#### Seal Minder®

The pump shall be supplied with a **Seal Minder**; to detect the presence of water in the seal oil chamber. The probe is connected to a 9VDC power source (by operator). The probe in the seal chamber measures the resistance in the fluid (oil). If the resistance drops below a preset amount, an alarm is triggered in the control panel.

#### Motor

The pump motor shall be designed specifically for submersible pump usage and continuous duty of pumped liquid up to 104 degrees F. The motor shall be an induction type, housed in an air-filled chamber. The stator windings and leads shall be insulated with moisture resistant Class H insulation rated for a maximum operating temperature of 356 degrees F.

The motor horsepower shall be non-overloading over the full range of the performance curve, from shut-off to run-out. The combined service factor (frequency, voltage and liquid specific gravity) of the motor shall be a minimum of 1.15.

# BJM PUMPS, LLC

## PUMP SPECIFICATION

### KZE HEAVY DUTY SLURRY PUMPS

The motor shall be protected from failure from overheating by two thermal sensor switches, set to open at 300 degrees F, embedded in the motor windings.

The motor cover housing shall have a threaded fitting to permit air testing of the motor and power cable inlet seal against leakage.

#### Power Cable

The pump shall be supplied with a 50 foot power cable connected to the motor lead wires, embedded and sealed in a water and oil resistant epoxy potting. The power cable shall be sized in accordance with NEC standards. The outer jacket of the power cable shall be made of oil resistant CPE, class GGC.

Optional: *(delete above and insert)*: The pump shall be supplied with a \_\_\_\_\_ foot power cable.

The power cable shall be protected by a strain relief chain, attached to the pump lifting handle. The strain relief chain will be sized to absorb the lifting load and prevent the power cable leads from being separated from their connection to the motor lead wires (if the power cable is pulled, as in the act of attempting to lift the pump by the cord).

#### Rotor Shaft

The rotor (pump) shaft shall be constructed of corrosive resistant 403SS and be of sufficient diameter to handle radial loads over the full range of the pump's performance curve while pumping water containing high concentrations of solids.

#### Supporting the Pump

The pump shall be mounted on an integral stand constructed of mild steel. The stand shall incorporate a strainer to prevent oversized solids from entering the pump.

The pump shall be fitted with lifting rings, screwed into the motor cover. Lifting chains shall be supplied by others.

#### **TESTING**

The pump shall undergo the following tests, which shall be recorded and certified.

Air pressure  
Noise  
Vibration

Winding: phase angle and impedance tests  
Insulation to ground

A copy of the test record tag shall be attached to the pump when delivered to the customer or job site.

# **BJM PUMPS, LLC**

## **PUMP SPECIFICATION**

### **KZE HEAVY DUTY SLURRY PUMPS**

#### **OVERALL**

The pump shall be a BJM Pumps KZE series model \_\_\_\_\_.

The pump shall be \_\_\_\_\_ inches in height, \_\_\_\_\_ inches in diameter and shall weigh \_\_\_\_\_ lbs.